

			,		· · · · · · · · · · · · · · · · · · ·
D	ITEM NO.	QTY.	PART NO. / DWG. NO.	MATERIAL	DESCRIPTION
	1	1	D-1111	STAINLESS STEEL	BACK CASING ASSEMBLY
	2	1	D-1110	STAINLESS STEEL	FRONT COVER
	3	1	JTK6-FM	COPPER / BRASS	HEATER TUBE ASSEMBLY
	4				
	5	6	N1315-6000T4	INCOLOY / BRASS	HEATING ELEMENT, 6000W @ 480V
	6	1	D-1114	ALUMINUM	TOP HEATER TUBE SUPPORT
	7	6	L93	VARIOUS	HI-LIMIT SWITCH, AUTO RESET (SET TO 200°F)
	8	1	TK FLOW BR	BRASS	FLOW METER, 0.2-8 GPM
	9				
	10	1	TK2250	VARIOUS	ELECTRONIC TEMPERATURE CONTROLLER
	11	1	TKD2000	VARIOUS	LED DISPLAY
	12	6	TG40E80	VARIOUS	TRIAC
	13	2	USP9509	VARIOUS	THERMISTOR
	14	AS REQ'D		COPPER	WIRE: POWER: #10 AWG, CONTROL: #18 AWG, THHN (90°C)
	15	1	KA-4C	COPPER	GROUND LUG
	16	1		POLYURETHANE	THERMISTOR INSULATION
	17				
	18	1	C25DNF340B	VARIOUS	MAGNETIC CONTACTOR, 208/240 VAC COIL, 50A RESISTIVE
С	19	1	B050-3299-3	VARIOUS	TRANSFORMER, 480/440 VAC TO 208 VAC
	20	3	PLUGBR 1/8	BRASS	DRAIN PLUG, 1/8" NPT
	21	5		RUBBER	INLET / OUTLET / DRAIN CASING GASKETS
	22	1	TANKLESS OVERLAY	LEXAN	DISPLAY OVERLAY
	23	1	COUPBELL 1/2" TO 3/4"	BRASS	INLET BELL COUPLING, 1/2" x 3/4"
	24	1	DIELECTRIC UNION	VARIOUS	DIELECTRIC UNION, 3/4" FNPT x 3/4" CTS
	25				
-	26	1		STAINLESS STEEL	INLET SCREEN (NOT SHOWN)
	27				
	28				
	29	1		VARIOUS	LEAK DETECTION WIRE
	30	AS REQ'D		RUBBER	GASKET MATERIAL (NOT SHOWN)
В	31	1	NIPPBR 3/4 X 1.5	BRASS	NIPPLE 3/4" x 1 1/2" LONG
	32	1	LGR-3	VARIOUS	CONTROL CIRCUIT FUSE, 3A
	33	1	LHR000	VARIOUS	FUSE HOLDER

INSTALLATION NOTES:

TANKLESS WATER HEATERS ARE CONSIDERED A NON-CONTINUOUS LOAD

IF MULTIPLE FEED INSTALLATION IS USED, IT IS ACCEPTABLE TO INSTALL UP TO TWO CONDUCTORS IN ONE LINE SIDE PORT. ADDITIONALLY, WHEN A POWER DISTRIBUTION BLOCK IS SUPPLIED, ADDITIONAL CONDUCTORS MAY BE INSTALLED IN AN OPEN LOAD SIDE PORT OF THE POWER DISTRIBUTION BLOCK.

WIRING SIZING LISTED IS FOR 75°C THHN. 60°C OR 90°C WIRE MAY BE USED. REFER TO NEC TABLE 310.16 FOR SIZING.

CONDUCTORS SHOULD BE SIZED TO MAINTAIN A VOLTAGE DROP OF LESS THAN 3% UNDER LOAD.

GENERAL NOTES:

- HEATING CHAMBER IS RATED FOR 150 PSI WATER PRESSURE (MAX.)
- UNIT IS UL, CUL, AND UL ÉPH LISTED.
- JTX FLOW RATE: 0.2 GPM MIN., 8 GPM MAX.
- APPROXIMATE WEIGHT IS 18 POUNDS.
- HEATERS ARE FULLY MODULATING FROM 0 TO 100%.
- UNIT IS DESIGNED FOR 50/60 Hz.

	ZONE	REV.			DESCRIPTION			DATE	APPROVED		
REVISIONS											
DATE NAME			Stratford, CT 06615 (203) 378-2659								
DRAW	/N	11.	/17/10 PRD								
CHECKED		11,	/22/10	SW	The Electric Heater Company						
ENG APPR.		11/	/22/10	PRD	Customer:						Α
MFG APPR. 11/22/10 WEN III				WEN III	Description:						
DIMENSIONS ARE IN INCHES					TANKLESS ELECTRIC BOOSTER HEATER, 36 kW @ 480 V, 3Ph						
TOLERANCES: (UNLESS OTHERWISE SPECIFIED)					SIZE	DWG.				REV	
FRACTIONAL ±¼ ANGULAR: MACH ±½° BEND ±1° TWO PLACE DECIMAL ±0.01 THREE PLACE DECIMAL ±0.005					B JTX036-6T4						
					SCALE	E: 1:1	FSCM: 198	357	SHEE	T 2 OF 2	

INSTALLATION PARAMETERS VOLTS 480 V **POWER** 36 kW AMP 43.3 A BREAKER SIZE(MIN) 50 A FEED WIRE SIZE(MIN) #8 AWG CONDUIT SIZE(MIN) 3/4" WIRING DIAGRAM 9

DRAWN

ENG APPR. MFG APPR.

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS

DRAWING IS THE SOLE PROPERTY OF THE ELECTRIC HEATER COMPANY. ANY

WITHOUT THE WRITTEN PERMISSION OF THE ELECTRIC HEATER COMPANY IS

REPRODUCTION IN PART OR AS A WHOLE

3