

_	(U	, ,	0	
	ITEM NO.	QTY.	PART NO. / DWG. NO.	MATERIAL	DESCRIPTION
	1	1	D-1111	STAINLESS STEEL	BACK CASING ASSEMBLY
	2	1	D-1110	STAINLESS STEEL	FRONT COVER
	3	1	JTK6-FM	COPPER / BRASS	HEATER TUBE ASSEMBLY
	4				
D	5	6	N1375-8000R		HEATING ELEMENT, 8000W @ 208V
	6	1	D-1114	ALUMINUM	TOP HEATER TUBE SUPPORT
	7	6	L93	VARIOUS	HI-LIMIT SWITCH, AUTO RESET (SET TO 200°F)
	8	1	TK FLOW BR	BRASS	FLOW METER, 0.2-8 GPM
	9				
	10	1	TK2250	VARIOUS	ELECTRONIC TEMPERATURE CONTROLLER
	11	1	TKD2000	VARIOUS	LED DISPLAY
	12	6	TG40E60	VARIOUS	TRIAC
	13	2	USP9509	VARIOUS	THERMISTOR
	14	AS REQ'D		COPPER	WIRE: POWER: #10 AWG, CONTROL: #18 AWG, THHN (90°C)
	15	1	KA-4C	COPPER	GROUND LUG
	16	1		POLYURETHANE	THERMISTOR INSULATION
	17			==	
	18	2	C25FNF360B	VARIOUS	MAGNETIC CONTACTOR, 208/240 VAC COIL, 75A RESISTIVE
С	19				
	20	3	PLUGBR 1/8	BRASS	DRAIN PLUG, 1/8" NPT
	21	5		RUBBER	INLET / OUTLET / DRAIN CASING GASKETS
	22	1	TANKLESS OVERLAY	LEXAN	DISPLAY OVERLAY
	23	1	COUPBELL 1/2" TO 3/4"	BRASS	INLET BELL COUPLING, 1/2" x 3/4"
	24	1	DIELECTRIC UNION	VARIOUS	DIELECTRIC UNION, 3/4" FNPT x 3/4" CTS
	25				
-	26	1		STAINLESS STEEL	INLET SCREEN (NOT SHOWN)
	27				
Ī	28				
	29	1		VARIOUS	LEAK DETECTION WIRE
	30	AS REQ'D		RUBBER	GASKET MATERIAL (NOT SHOWN)
_	31	1	NIPPBR 3/4 X 1.5	BRASS	NIPPLE 3/4" x 1 1/2" LONG
В	32	1	LGR-3	VARIOUS	CONTROL CIRCUIT FUSE, 3A
	33	1	LHR000	VARIOUS	FUSE HOLDER
T					

- HEATING CHAMBER IS RATED FOR 150 PSI WATER PRESSURE (MAX.)
- UNIT IS UL, CUL, AND UL ÉPH LISTED.

GENERAL NOTES:

- JTX FLOW RATE: 0.2 GPM MIN., 8 GPM MAX.
- APPROXIMATE WEIGHT IS 18 POUNDS.
- HEATERS ARE FULLY MODULATING FROM 0 TO 100%.
- UNIT IS DESIGNED FOR 50/60 Hz.

Installation parameters				
VOLTS	208 V			
POWER	48 kW			
AMP	133.2 A			
BREAKER SIZE(MIN)	150 A			
FEED WIRE SIZE(MIN)	1/0 AWG			
CONDUIT SIZE(MIN)	1 1/4"			
WIRING DIAGRAM	12			

INSTALLATION NOTES:

- TANKLESS WATER HEATERS ARE CONSIDERED A NON-CONTINUOUS LOAD
- IF MULTIPLE FEED INSTALLATION IS USED, IT IS ACCEPTABLE TO INSTALL UP TO TWO CONDUCTORS IN ONE LINE SIDE PORT. ADDITIONALLY, WHEN A POWER DISTRIBUTION BLOCK IS SUPPLIED, ADDITIONAL CONDUCTORS MAY BE INSTALLED IN AN OPEN LOAD SIDE PORT OF THE POWER DISTRIBUTION BLOCK.
- WIRING SIZING LISTED IS FOR 75°C THHN. 60°C OR 90°C WIRE MAY BE USED. REFER TO NEC TABLE 310.16 FOR SIZING.
- CONDUCTORS SHOULD BE SIZED TO MAINTAIN A VOLTAGE DROP OF LESS THAN 3% UNDER LOAD.
- THESE MODELS INDICATED REQUIRE THAT A SUPPLEMENTARY PROTECTION ASSEMBLY BE INSTALLED (SUPPLIED BY HUBBELL). IF SUPLLEMENTAL PROTECTION IS SUPPLIED BY OTHERS, WHERE MULTIPLE FEEDER CONNECTIONS ARE USED, PHASES MUST BE FROM THE SAME SOURCE.

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF THE ELECTRIC HEATER COMPANY. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF THE ELECTRIC HEATER COMPANY IS

DATE APPROVED ZONE REV. DESCRIPTION REVISIONS DATE NAME (203) 378-2659 PRD 11/17/10 The Electric Heater Company SW 11/22/10 PRD Customer: 11/22/10 11/22/10 WEN III Description: TANKLESS ELECTRIC BOOSTER HEATER, 48 kW @ 208 V, 3Ph DIMENSIONS ARE IN INCHES SIZE DWG. NO. TOLERANCES: (UNLESS OTHERWISE SPECIFIED) REV FRACTIONAL ±1/4 JTX048-6R ANGULAR: MACH ±½° BEND ±1° TWO PLACE DECIMAL ±0.01 THREE PLACE DECIMAL ±0.005 SCALE: 1:1 | FSCM: 19857 SHEET 2 OF 2

CHECKED ENG APPR. MFG APPR.

3