

	•	3	1 '	O	3
	ITEM NO.	QTY.	PART NO. / DWG. NO.	MATERIAL	DESCRIPTION
	1	1	D-1111	STAINLESS STEEL	BACK CASING ASSEMBLY
	2	1	D-1110	STAINLESS STEEL	FRONT COVER
	3	1	JTK6-FM	COPPER / BRASS	HEATER TUBE ASSEMBLY
	4				
D	5	6	N1375-8000R		HEATING ELEMENT, 8000W @ 208V
	6	1	D-1114	ALUMINUM	TOP HEATER TUBE SUPPORT
	7	6	20603L13-44	VARIOUS	HI-LIMIT SWITCH, AUTO RESET (SET TO 200°F)
	8	1	TK FLOW BR	BRASS	FLOW METER, 0.2-8 GPM
	9				
	10	1	TK2250	VARIOUS	ELECTRONIC TEMPERATURE CONTROLLER
	11	1	TKD2000	VARIOUS	LED DISPLAY
	12	6	TG40E60	VARIOUS	TRIAC
	13	2	USP9509	VARIOUS	THERMISTOR
	14	as req'd		COPPER	WIRE: POWER: #8 AWG, CONTROL: #18 AWG, THHN (90°C)
	15	1	KA-4C	COPPER	GROUND LUG
	16	1		POLYURETHANE	THERMISTOR INSULATION
	17	2	67572	VARIOUS	POWER DISTRIBUTION BLOCK
1	18				
С	19				
	20	3	PLUGBR 1/8	BRASS	DRAIN PLUG, 1/8" NPT
	21	5		RUBBER	INLET / OUTLET / DRAIN CASING GASKETS
	22	1	TANKLESS OVERLAY	LEXAN	DISPLAY OVERLAY
1	23	1	COUPBELL 1/2" TO 3/4"	BRASS	INLET BELL COUPLING, 1/2" x 3/4"
	24	1	DIELECTRIC UNION	VARIOUS	DIELECTRIC UNION, 3/4" FNPT x 3/4" CTS
	25	 1		 OT A IN II FOO OTFF!	
-	26	1		STAINLESS STEEL	INLET SCREEN (NOT SHOWN)
	27				
ı	28				
İ	29	1		VARIOUS	LEAK DETECTION WIRE
	30	AS REQ'D		RUBBER	GASKET MATERIAL (NOT SHOWN)
_	31	1	NIPPBR 3/4 X 1.5	BRASS	NIPPLE 3/4" x 1 1/2" LONG
В	32	1	LGR-3	VARIOUS	CONTROL CIRCUIT FUSE, 3A
	33	1	LHR000	VARIOUS	FUSE HOLDER

INSTALLA	I NOIT	NOTES:

TANKLESS WATER HEATERS ARE CONSIDERED A NON-CONTINUOUS LOAD.

IF MULTIPLE FEED INSTALLATION IS USED. IT IS ACCEPTABLE TO INSTALL UP TO TWO CONDUCTORS IN ONE LINE SIDE PORT. ADDITIONALLY, WHEN A POWER DISTRIBUTION BLOCK IS SUPPLIED, ADDITIONAL CONDUCTORS MAY BE INSTALLED IN AN OPEN LOAD SIDE PORT OF THE POWER DISTRIBUTION BLOCK.

3. WIRING SIZING LISTED IS FOR 75°C THHN. 60°C OR 90°C WIRE MAY BE USED. REFER TO NEC TABLE 310.16 FOR SIZING.

CONDUCTORS SHOULD BE SIZED TO MAINTAIN A VOLTAGE DROP OF LESS THAN 3%

THESE MODELS INDICATED REQUIRE THAT A SUPPLEMENTARY PROTECTION ASSEMBLY BE INSTALLED (SUPPLIED BY HUBBELL). IF SUPLLEMENTAL PROTECTION IS SUPPLIED BY OTHERS, WHERE MULTIPLE FEEDER CONNECTIONS ARE USED, PHASES MUST BE FROM

REVISIONS DATE NAME PRD 11/17/10

DESCRIPTION

(203) 378-2659 The Electric Heater Company

PRD Customer: ENG APPR. 11/22/10 11/22/10 WEN III MFG APPR. Description:

11/22/10

SW

ZONE REV.

DRAWN

CHECKED

FRACTIONAL ±1/4

GENERAL NOTES:

HEATING CHAMBER IS RATED FOR 150 PSI

JTX FLOW RATE: 0.2 GPM MIN., 8 GPM MAX.

UNIT IS UL, CUL, AND UL ÉPH LISTED.

UNIT IS DESIGNED FOR 50/60 Hz.

APPROXIMATE WEIGHT IS 18 POUNDS. HEATERS ARE FULLY MODULATING

WATER PRESSURE (MAX.)

FROM 0 TO 100%.

TANKLESS ELECTRIC BOOSTER HEATER, 48 kW @ 208 V, 1Ph DIMENSIONS ARE IN INCHES

TOLERANCES: (UNLESS OTHERWISE SPECIFIED) ANGULAR: MACH ±½° BEND ±1° TWO PLACE DECIMAL ±0.01 THREE PLACE DECIMAL ±0.005

SIZE DWG. NO. REV JTX048-6RS SCALE: 1:1 | FSCM: 19857 SHEET 2 OF 2

UNDER LOAD. THE SAME SOURCE.

INSTALLATION PARAMETERS

208 V

48 kW

230.8 A

250 A

250 AWG

6

VOLTS

POWER

AMP

BREAKER SIZE(MIN)

FEED WIRE SIZE(MIN)

CONDUIT SIZE(MIN)

WIRING DIAGRAM

DATE APPROVED

3

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS

THE ELECTRIC HEATER COMPANY. ANY

WITHOUT THE WRITTEN PERMISSION OF THE ELECTRIC HEATER COMPANY IS

REPRODUCTION IN PART OR AS A WHOLE

DRAWING IS THE SOLE PROPERTY OF